



CL-1B (CRUSHED STONE GRADATION CA-6)
MATERIAL BEDDING SHALL BE COMPACTED
TO A MINIMUM OF 95% IN ACCORDANCE
WITH ASTM 2321-89

N.S.S.D. SANITARY SEWER
PIPE BEDDING DETAIL

NOT TO SCALE